

Ref: INS/L-5240/2019-2020(Y)

Date : 19/07/2019

### ENQUIRY

Dear Sirs,  
Please let us have your lowest Quotation for the following :

| Sl.No | Cat.No | Item Description                                   | Make/Model | Item Qty | UOM |
|-------|--------|--|------------|----------|-----|
| 1     |        | Electrical Panel as per the specification enclosed | --         | 1.00     | No. |

#### Remarks :

#### Note :

1. The bids shall be enclosed in an envelope , and due date sealed duly marked "Tender for \_\_\_\_\_" Ref No : \_\_\_\_\_. The bids should be addressed and to be mailed to "**THE HEAD-PURCHASE**". The bids are liable to be rejected if the sealed envelope is not addressed to "**THE HEAD-PURCHASE**" with Tender Ref No and Item Description and due date. The bids delivered in person shall be dropped in Purchase Section. If the bids are sent through courier or mail , it should reach by submission Date and Time and inStem will not be responsible for the delay.

#### 2. DUE DATE FOR SUBMISSION OF QUOTATION AGAINST THIS ENQUIRY IS

23/07/2019 till 5.30 p.m.

3. QUOTATIONS RECEIVED AFTER THE DUE DATE SHALL BE REJECTED.

4. The Validity of your quotation should be for 60 days from the date.

5. All duties, taxes, surcharge and cess as currently applicable must be stated in your quotation, separately. Otherwise your quote is liable to be rejected.

6. Your quotation should indicate delivery period & Warranty period.

7. Delivery to be made to our Stores. Please indicate charges, if any extra. Transit Insurance should be done upto inStem Stores.

8. If you are unable to supply the quality, specifications or brand as mentioned in our enquiry, Please state so and then offer alternative to quality/Specifications.

9. Payment : within one month after delivery & acceptance/satisfactory installation.

10. Please ensure that the enquiry number and the due date is superscribed on the envelope failing which your quotation is liable to be rejected.

11. Since we are a public funded research institution, we are exempted from paying Customs Duty (Except ad valorem duty of 5% + 2% cess and CVD @4% vide Notification No.51/96 with latest amendments) and excise duty vide Notification No.10/97 CENTRAL EXCISE dated 01-03-1997 for all scientific equipments, technical instruments, equipments (including computers), their accessories, spares, consumables and software. Hence, please offer your prices taking this option into consideration.

If the items as per specifications in our P.O. is not supplied (shipped) within the specified delivery schedule, then liquidated damages (not in terms of penalty) will be imposed automatically and shall be deducted from the bill at the rate of 0.5% per week subject to a maximum of 10% of the order value.



**Institute For Stem Cell Biology and Regenerative Medicine**

Autonomous institute of the Department of Biotechnology, Government Of India



Ref: INS/L-5240/2019-2020(Y)


Date : 19/07/2019

**12.If the item is covered under DGS&D rate contract,please quote the rate as per the DGS&D rate contract with xerox copy of the DGS&D order.**

13.Any dispute or differences that may arise between the parties shall be referred to the sole arbitration of the Centre Director or his nominees.The decision of the arbitrator shall be final and binding on the parties.The venue for arbitration shall be Bangalore.The provisions of the Arbitration and Concillation Act,1996 as amended from time to time shall apply.The Courts in Bangalore shall have exclusive jurisdiction to deal with any or all disputes between the parties.

Yours faithfully

For and on behalf of Insitute For Stem Cell  
Biology and Regenerative Medicine

  
Yesu R

GKVK, Bellary Road, Bangalore-560065,INDIA

Phone No. : 91-80-23666343/344/345/346

Fax : 91-80-23636662

Email Id: purchase@ncbs.res.in

Website : www.ncbs.res.in



| INS/L-5240/2019-2020(Y)   |     |     |
|---|-----|-----|
| in-Stem CIFF UPS INPUT PANEL SPECIFICATION  | Qty |     |
| Supply, installation, Testing and Commissioning of 3phase and Neutral 415V, 4 wire Free Standing, Floor mounted MV panel made out of 2mm thick CRCA sheet after seven tank process and Epoxy powder coating. The panel shall consist of suitable rating TPN Aluminium busbar (at the rating of 0.8A per Sq.mm) supported with DMC/ SMC barriers and color coded with Heat shrinkable sleeves. The Metering shall be provided as specified. The panel shall have Short circuit with standing capacity of minimum 50KA and consist of the switch gear as mentioned below. The panel shall be got fabricated from manufacturers with CPRI Test certificate only. The PCC shall have at least two spare cubicles of the maximum outgoing MCCB rating. The Panels shall be mounted on ISMC-75 including supply and fixing of the same. |     |     |
| Incoming- DN1-250N, L&T, TPMCCB with thermal magnetic (160-200A) overload and Sc prot, 50kA   | 1   | no  |
| Bus bars : 250A TPN Aluminium Bus bars with 100% neutral – 4Sets, R,Y,B,N, (30x10mm 1runs each phase, earthing 1run of 25x6mm)  |     |     |
| Outgoings:  |     |     |
| DN0-100D, L&T, TPMCCB with thermal magnetic (32-40A) overload and Sc prot 36kA  | 5   | nos |
| 25A FP MCB, 415VAc, 50 Hz, 10kA. 'D'  | 1   | no  |
| 32A SP MCB, 415VAc, 50 Hz, 10kA. 'D'  | 16  | nos |
| 40A SPN MCB, 415VAc, 50 Hz, 10kA. 'D'   | 3   | nos |
| Metering :  |     |     |
| Digital multi function meter with CTS   | 2   | nos |
| LED type Phase indication lamps with individual TPMCB control and toggle switches as per the drawing,   |     |     |
|   | nos | 1   |

