

Ref: INS/L-5371/2018-2019(Y)

Date : 01/08/2018

ENQUIRY

Dear Sirs,

Please let us have your lowest Quotation for the following :

Sl.No	Cat.No	Item Description	Make/Model	Item Qty	UOM
1		Signage LED Up Lighter – Out Door Type (Specifications Attached)	Ligman, Wipro or equivalent, Litolux, schreder, eq	4.00	Nos.

Remarks :

Note :

1. The bids shall be enclosed in an envelope , and due date sealed duly marked "Tender for _____" Ref No : _____. The bids should be addressed and to be mailed to "**THE HEAD-PURCHASE**". The bids are liable to be rejected if the sealed envelope is not addressed to "**THE HEAD-PURCHASE**" with Tender Ref No and Item Description and due date. The bids delivered in person shall be dropped in Purchase Section. If the bids are sent through courier or mail , it should reach by submission Date and Time and inStem will not be responsible for the delay.

**2. DUE DATE FOR SUBMISSION OF QUOTATION AGAINST THIS ENQUIRY IS
07/08/2018 till 5.30 p.m.**

3. QUOTATIONS RECEIVED AFTER THE DUE DATE SHALL BE REJECTED.

4. The Validity of your quotation should be for 60 days from the date.

5.All duties,taxes,surcharge and cess as currently applicable must be sated in your quotation,seperately.Otherwise your quote is liable to be rejected.

6.Your quotation should indicate delivery period & Warranty period.

7.Delivery to be made to our Stores.Please indicate charges,if any extra.Transit Insurance should be done upto inStem Stores.

8.If you are unable to supply the quality,specifications or brand as mentioned in our enquiry,Please state so and then offer alternative to quality/Specifications.

9.Payment :within one month after delivery & acceptance/satisfactory installation.

10.Please ensure that the enquiry number and the due date is superscribed on the envelope failing which your quotation is liable to be rejected.

11.Since we are a public funded research institution,we are exempted from paying Customs Duty(Except advolerum duty of 5% + 2% cess and CVD @4% vide Notification No.51/96 with latest amendments) and excise duty vide Notification No.10/97 CENTRAL EXCISE dated 01-03-1997 for all scientific equipments,technical instruments,equipments(including computers),their accessories,spares,consumables and software.Hence,please offer your prices taking this option into consideration.



Institute For Stem Cell Biology and Regenerative Medicine

Autonomous institute of the Department of Biotechnology, Government Of India



Ref: INS/L-5371/2018-2019(Y)

Date : 01/08/2018

12.If the item is covered under DGS&D rate contract,please quote the rate as per the DGS&D rate contract with xerox copy of the DGS&D order.

13.Any dispute or differences that may arise between the parties shall be referred to the sole arbitration of the Centre Director or his nominees.The decision of the arbitrator shall be final and binding on the parties.The venue for arbitration shall be Bangalore.The provisions of the Arbitration and Concillation Act,1996 as amended from time to time shall apply.The Courts in Bangalore shall have exclusive jurisdiction to deal with any or all disputes between the parties.

Yours faithfully

For and on behalf of Insitute For Stem Cell
Biology and Regenerative Medicine

A handwritten signature in blue ink, appearing to read 'Yesu R'.

Yesu R

GKVK, Bellary Road, Bangalore-560065,INDIA

Phone No. : 91-80-23666343/344/345/346

Fax : 91-80-23636662

Email Id: purchase@ncbs.res.in

Website : www.ncbs.res.in



Signage LED Up Lighter – Out Door Type

Specifications:

- Die-cast aluminum, compact, aesthetic, powder coated housing.
- IP66 or more, optically sealed housing with toughened glass totally sealed using silicon gasket ensuring IP and lifelong performance
- High efficiency LEDs mounted on black anodized aluminum heat sink for effective heat dissipation
- Special high efficiency optical grade UV stabilized engineering plastic reflector
- Adjustable beam angle in stages, with desired angle between 30 to 40 deg.
- Inbuilt 2 stage, IP66 or more CCCV electronic driver with 2kV surge protection
- Maintainable with vandal resistant structure giving access to driver and LED
- Anti corrosive stainless steel hardware facilitates maintenance.
- Conforms to IS 10322 or CE certified
- Complete with LEDs and driver pre-wired up to terminal block
- With necessary GFP mains connector
- High efficiency LED fixture, 3 -10 Watts, 230 Volts, Minimum 150 Lumens output in total, Colour – 3000K - 4500K, Non dimmable.

Mounting

- Cradle mounting

Accessories

- Directional shield
- Earth spike in die-cast aluminum

Warranty

- Minimum 1 year replacement warranty.

