



Ref: INS/L-5568/2018-2019(Y)

Date : 06/09/2018

ENQUIRY

Dear Sirs,

Please let us have your lowest Quotation for the following :

SI.No	Cat.No	Item Description	Make/Model	Item Qty	UOM
1		Supply, Installation, Testing and Commissioning of class 100 air shower complete with stainless steel housing, hepa filters all necessary controls, doors as per the design drawings, inter locks etc. as per the specifications. Air shower shall be of following characteristics as per enclosed specification and BOQ, a. Straight Opening b. Size : 1080mm(L)x980mm(W)x2700mm(H) c. Number of nozzles : 12 d. Number of doors : 2 (Size 830mm Width)		1.00	Nos.
2		Supply, Installation, Testing and Commissioning of class 100 air shower complete with stainless steel housing, hepa filters all necessary controls, doors as per the design drawings, inter locks etc. as per the specifications. Air shower shall be of following characteristics : a. 90 deg Opening (L-Type) b. Size : 1110mm(L)x1025mm(W)x2700mm(H) c. Number of nozzles : 12 d. Number of doors : 2 (Specifications Attached)		1.00	Nos.

Ref: **INS/L-5568/2018-2019(Y)**

Date : 06/09/2018

Remarks : The Price quoted against this RFQ should be extended to Bangalore Life Science Cluster (BLiSc) of NCBS, InStem and C-CAMP for placing repeat order as per norms, by any one or all institutes of Bangalore Life Science Cluster (BLiSc). **inStem is a public funded research institute and is entitled to concessional rate of GST @ 5% for items supplied for research purpose. The offer should be submitted after fully considering the above notification. **

Note : The Tenders to be quoted in foreign currencies & any other currencies approved/traded by RBI - USD/Euro/JPY/GBP/SGD/CAD/INR.

1. The bids shall be enclosed in an envelope , and due date sealed duly marked "Tender for _____" Ref No : _____. The bids should be addressed and to be mailed to "THE HEAD-PURCHASE". The bids are liable to be rejected if the sealed envelope is not addressed to "THE HEAD-PURCHASE" with Tender Ref No and Item Description and due date. The bids delivered in person shall be dropped in Purchase Section. If the bids are sent through courier or mail , it should reach by submission Date and Time and inStem will not be responsible for the delay.

**2. DUE DATE FOR SUBMISSION OF QUOTATION AGAINST THIS ENQUIRY IS
20/09/2018 till 2.30 p.m.**

3. QUOTATIONS RECEIVED AFTER THE DUE DATE SHALL BE REJECTED.

4. The Validity of your quotation should be for 60 days from the date.

5. All duties, taxes, surcharge and cess as currently applicable must be stated in your quotation, separately. Otherwise your quote is liable to be rejected.

6. Your quotation should indicate delivery period & Warranty period.

7. Delivery to be made to our Stores. Please indicate charges, if any extra. Transit Insurance should be done upto inStem Stores.

8. If you are unable to supply the quality, specifications or brand as mentioned in our enquiry, Please state so and then offer alternative to quality/Specifications.

9. Payment : within one month after delivery & acceptance/satisfactory installation.

10. Please ensure that the enquiry number and the due date is superscribed on the envelope failing which your quotation is liable to be rejected.

11. Since we are a public funded research institution, we are exempted from paying Customs Duty (Except ad valorem duty of 5% + 2% cess and CVD @ 4% vide Notification No. 51/96 with latest amendments) and excise duty vide Notification No. 10/97 CENTRAL EXCISE dated 01-03-1997 for all scientific equipments, technical instruments, equipments (including computers), their accessories, spares, consumables and software. Hence, please offer your prices taking this option into consideration.



Institute For Stem Cell Biology and Regenerative Medicine
Autonomous institute of the Department of Biotechnology, Government Of India



Ref: INS/L-5568/2018-2019(Y)

Date : 06/09/2018

12.If the item is covered under DGS&D rate contract,please quote the rate as per the DGS&D rate contract with xerox copy of the DGS&D order.

13.Any dispute or differences that may arise between the parties shall be referred to the sole arbitration of the Centre Director or his nominees.The decision of the arbitrator shall be final and binding on the parties.The venue for arbitration shall be Bangalore.The provisions of the Arbitration and Concillation Act,1996 as amended from time to time shall apply.The Courts in Bangalore shall have exclusive jurisdiction to deal with any or all disputes between the parties.

Yours faithfully

For and on behalf of Insitute For Stem Cell
Biology and Regenerative Medicine

Yesu R



GKVK, Bellary Road, Bangalore-560065,INDIA

Phone No. : 91-80-23666343/344/345/346

Fax : 91-80-23636662

Email Id: purchase@ncbs.res.in

Website : www.ncbs.res.in

1	AIR SHOWER				
	Particulars		Unit		
	Supply, Installation, Testing and Commissioning of class 100 air shower complete with stainless steel housing, hepa filters all necessary controls, doors as per the design drawings, inter locks etc. as per the specifications. Air shower shall be of following characteristics :				
I	a. Straight Opening				
	b. Size : 1080mm(L)x980mm(W)x2700mm(H)				
	c. Number of nozzles : 12				
	d. Number of doors : 2 (Size 830mm Width)				
	Air shower as described above.	No	1		
II	a. 90 deg Opening (L-Type)				
	b. Size : 1110mm(L)x1025mm(W)x2700mm(H)				
	c. Number of nozzles : 12				
	d. Number of doors : 2				
	Air shower as described above.	No	1		
NOTE : Before quoting vendors are requested to visit the site to get the actual measurement					

AIR SHOWER SPECIFICATIONS	
	Air Shower shall be made of Stainless steel material compatible with clean room application. Walls of air shower shall be hard, durable and non-particulating.
	CONSTRUCTION
	i. Prefabricated wall and roof sections with integral air duct plenums.
	ii. Units shall be self contained, self supporting, capable of supporting a minimum of 200 lbs per square foot with a maximum deflection of .25".
	iii. Maintenance access shall be from the ends, sides or from above.
	iv. Access panels shall be provided on the access sides that are selected by the customer.
	v. The mechanical section of the air shower shall contain blower/motor units, air nozzles, HEPA filters, and electrical controls.

